

# Invoice

Issued: 10/06/2021

Due: 11/05/2021

Pool Leak #224979

**BILL TO**

**Castle by the Sea Motel**  
4520 N Ocean Dr  
Lauderdale by the Sea, FL  
33308

**JOB SITE**

**Castle by the Sea Motel**  
4520 N Ocean Dr  
Lauderdale by the Sea, FL  
33308

**BALANCE DUE**

**\$0.00**

DESCRIPTION OF WORK	QUANTITY	PRICE	TAX	TOTAL
<b>Commercial Pool Leak Detection</b>	1.00	\$495.00	\$0.00	\$495.00

- Includes testing of the pool shell, plumbing lines and equipment
- 60 day warranty

**Note:** Bodies of water can lose up to 1/4 inch a day from evaporation under normal operating conditions.

*Disclaimer: Fees for services will apply if water loss is due to evaporation.*

*Disclaimer: Red Rhino Leak Detection is not responsible for the purchase or replacing of gutter grates that have been Diamond Brited over or that have rusted screws. All gutter grates will have to be removed at the time of inspection in order to pressure test the gutter lines.*

Subtotal:	<b>\$495.00</b>
Tax:	<b>\$0.00</b>
Payments:	<b>\$495.00</b>



Payment History

DATE	PAYMENT TYPE	STATUS	CHECK #	DESCRIPTION	NOTES	AMOUNT
Feb 15, 2024	Check	Paid	674	No description	No notes	\$495.00

📅 WEDNESDAY, OCTOBER 6, 2021

## Deck/Surface/Equipment

Description of deck and surface. equipment.

Deck:

Concrete Surface: Sky Blue Picture of pool



## Equipment - Heater - Inside

Found leak inside heater. Heater needs to be serviced. &nbsp;



## Test - Complete Dye Test

Performed a complete dye test in the pool. Everything appears to be solid.

---

## Leak Status - Leaking

The pool will continue to leak at the same rate until repairs are completed.

---

## Miscellaneous

Gutters are all sealed in. Grates need be removed/broken out in order to properly test.



📅 THURSDAY, NOVEMBER 4, 2021

### Test - Water Loss - Set Up

Marked water level in pool. Water loss results will be confirmed by a (phone call).



---

📅 SATURDAY, NOVEMBER 6, 2021

### Test - Water Loss - Results - Not Leaking

Confirmed water level is holding solid. The pool is not leaking. However the gutters now do need to be broken out to properly test.

---

📅 TUESDAY, NOVEMBER 9, 2021

## Miscellaneous

Gutters are not connected to the pump. When pressure testing the gutter line from the pump, the pressure quickly builds and holds before getting to the gutters. This indicates that the gutter line is capped underground. Instead of gutters working as normal, these gutters act like an overflow. When water is added to gutters, the water is sent to waste.



---

## Test - Water Loss - Set Up

Marked water level in pool. Water loss results will be confirmed by a (phone call) on (11/10).



 THURSDAY, NOVEMBER 11, 2021

### **Test - Water Loss - Results - Not Confirmed**

Attempts were made. At this time, the results have not been confirmed, and Red Rhino will wait to hear from the homeowner if needed.

## Warranties & Disclaimers

Payment is expected at time of service. License **#CPC1457457**

**Note:**

Customer is responsible for refilling water and balancing chemicals. Please monitor water levels for 48 hours. Contact RRLD with any questions or concerns.

**Change Order Disclaimer:**

A change order will be issued if RRLD discovers any unforeseen or unexpected work not specified above. An additional quote will be issued at that time.

**Deck Disclaimer:**

RRLD does not offer custom staining or textures. We will make every attempt to match the deck when applying deck patches. If an exact match is desired (color and texture), customer will need to hire a professional deck company to apply the patch.

**Patch Disclaimer:**

Red Rhino Leak Detection (RRLD) will make every attempt to match the existing surface when applying patches. However, due to variations of the product from the manufacturer and aging of the existing surface, it is impossible to achieve an exact match when patching. Refinishing the entire surface is the only way to ensure a consistent appearance without variation. Therefore, RRLD cannot be held responsible for color and texture variations which are unavoidable when patching.

## Sign Invoice

Please sign and date below for approval and return via email([redrhinocsr@redrhino.com](mailto:redrhinocsr@redrhino.com)) or fax(561-692-4814). All scheduling is on a first come first serve basis. We will contact you regarding scheduling upon receipt of the signed document

*X*

*Date*

*Printed Name*